

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 178/25

Date : 25/2/25

It is certified that an inspection team headed by Shibu Bhaskar m.B
Health Inspector, Taluk Hospital, Njarakkal (Name of Officers
with designation) from Taluk Hospital, Njarakkal (Name of
Department/Office) inspected the ASSISSI VIDYA
NIKETHAN PUBLIC SCHOOL, NJARAKKAL (Name & Address of
the School) on 21/2/25 and found that the ASSISSI VIDYA
NIKETHAN PUBLIC SCHOOL (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of One year.

Signature with Seal : [Signature]

Name : Shibu Bhaskar m.B

Designation : Health Inspector

**HEALTH INSPECTOR
TALUK HOSPITAL, NJARAKKAL**

To

Manager

ASSISSI VIDYA NIKETHAN PUBLIC SCHOOL

NJARAKKAL

(Name & Address of the Institution)

[Signature]
Self attested

Administrator

**Assisi Vidyaniketan Public School
Perumpilly, Narakkal, Vypin-682505
vidyaniketanperumpilly@gmail.com**



Self attested
[Signature]

**ANITHA KURIAPPAN
PRINCIPAL**

**Assisi Vidyaniketan Public School
Perumpilly, Vypin - 682 505**



Telephone: 0484 2925768
email: qcSDLvypin@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, VYPIN - 682508
WATER TEST REPORT

Report No: KWA/QCSDL-VP/2753/10/24

Report Issue Date: 30.10.2024

Customer Name & Address ASSISI VIDYANIKETAN PUBLIC SCHOOL PERUMPILLY, NJARAKKAL	Date of Receipt of Payment	22.10.2024
	Date of Sample received	22.10.2024
	Sample given by	Customer
	Sample Code	VP/2753/10/24
	Sample Name	Drinking Water
	Sample Condition	Good
	Source of Sample	Tap Water (Filtered)
	Sample Quantity	2Ltr

Test performing date : 23.10.2024 TO 29.10.2024

Sl.No	Characteristics	Unit	Test Method	Acceptable Limit as per IS	Result
1	Turbidity	NTU	IS 3025 (Part 10)-2023	1.0	0.61
2	pH @ 25°C		IS 3025 (Part 11)-2022	6.5 to 8.5	7.70
3	Chloride (as Cl)	mg/L	IS 3025 (Part 32)-1988(Reaffirmed 2019)	250	2.08
4	Nitrate (as NO ₃)	mg/L	APHA 23rd Edition(UV Screening Method) 2017	45	2.08
5	Total Hardness (as CaCO ₃)	mg/L	IS 3025 (Part 21)-2009(Reaffirmed 2019)	200	18
6	Iron (as Fe)	mg/L	IS 3025 (Part 53)-2024	1	<0.1
7	Electrical conductivity at 25°C	µS/cm	IS 3025 (Part 14)-2013(Reaffirmed 2019)	-	57.00

Remarks:-

- 1) The result stated above related only to the sample(s) submitted for testing by the customer .
- 2) The samples retain for 15 days from the end date of analysis
- 3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory
- 4) BDL-Below Detection Limit
- 5) DL-Detectable Limit

Reviewed & Analysed By

Kemya E.R

End of Report

KWA/QCSDL/VP/F-21	Issue Date : 20.09.2021	
Rev No:02	Rev,Date : 01.07.2023	Page 1 of 1



Self attested

Amritha
Administrator
Assisi Vidyaniketan Public School
Perumpilly, Narakkal, Vypin-682505
vidyaniketanperumpilly@gmail.com



Self attested

ANITHA KURIAPPAN
PRINCIPAL
Assisi Vidyaniketan Public School
Perumpilly, Vypin - 682 505



Telephone:0484-2925765
email:qcsdlvypin@gmail.com

KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LAB, VYPIN - 682508
WATER TEST REPORT

Report No:KWA/QCSDL-VP/BC 2753/10/24

Report Issue Date: 30.10.2024

Customer Name &Address		Date of Receipt of Payment	22.10.2024	
ASSISI VIDYANIKETAN PUBLIC SCHOOL PERUMPILLY, NJARAKKAL		Date of Sample received	22.10.2024	
		Sample given by	Customer	
		Sample Code	VP/BC 2753/10/24	
		Sample Name	Drinking Water	
		Sample Condition	Good	
		Source of Sample	Tap Water	
		Sample Quantity	200ml	
		Test performing date : 24.10.2024 TO 25.10.2024		
Sl. No.	Source	Acceptable Limit as per IS 10500-2012	Test Method	Result
1	Total Coliform	Shall not be detected/100ml	IS15185-2016	Absent
2	E Coli	Shall not be detected/100ml	IS15185-2016	Absent

Remarks:-


- NB:- 1) The result stated above related only to the sample(s) submitted for testing by the customer.
2) The samples retain for 15 days from the end date of analysis
3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory

Reviewed & Analysed By

C.V Sreelakshmi
C.V Sreelakshmi

End of Report

KWA/QCSDL/VP/F-21	Issue Date : 20.09.2021	
Rev No: Nil	Rev.Date : Nil	Page 1 of 1



Self attested

[Signature]

Administrator
Assisi Vidyaniketan Public School
Perumpilly, Narakkal, Vypin-682505
vidyaniketanperumpilly@gmail.com



Self attested
[Signature]

ANITHA KURIAPPAN
PRINCIPAL
Assisi Vidyaniketan Public School
Perumpilly, Vypin - 682 505